



**Underwriters
Laboratories Inc.®**

Northbrook Division
333 Pfingsten Road
Northbrook, IL 60062-2096 USA
www.ul.com
tel: 1 847 272 8800
fax: 1 847 272 8129
Customer service: 1 877 854 3577

December 6, 2006

Mr. Phil Kemm
Transtank Pty Ltd
Suite 12 1020 Doncaster Rd
East Doncaster, Victoria 3109
Australia

E-mail: phil@hazkem.com.au

Reference: File MH45150

Products: "T" SERIES RECTANGULAR ABOVEGROUND SECONDARY CONTAINMENT TANKS FOR
FLAMMABLE AND COMBUSTIBLE LIQUIDS

Dear Mr. Kemm:

This confirms that the subject products have been investigated by Underwriters Laboratories Inc., have been found to comply with the applicable requirements of the current edition of UL142, Underwriters Laboratories Inc. Standard for Steel Aboveground Tanks for Flammable and Combustible Liquids, and ULC/ORD-C142.18-1995, Underwriters Laboratories of Canada Other Recognized Document for Rectangular Steel Aboveground Tanks for Flammable and Combustible Liquids, and are eligible to bear the UL Listing Mark if constructed in accordance with the UL Follow-Up Service Inspection Procedure, File MH45150, Volume 1 (UL Listing Report dated September 19, 2006 under File MH45150).

If you have any questions, please contact me.

Sincerely,

Tim Crews
Staff Engineer
Hazardous Locations, Gas & Oil
Tel: 847-664-2516
Fax: 847-313-2516
E-mail: timothy.a.crews@us.ul.com

An independent organization working for a safer world with integrity, precision and knowledge.

