

**SEPARATION DISTANCES FOR TRANTANKS
TO PROTECTED WORKS***

TANK SIZE (kL)	SEPARATION DISTANCE (m)	
	<u>C1</u>	<u>C2</u>
2.25	unrestricted	unrestricted
4.5	.8	unrestricted
12	3.2	1.4
17	3.7	2.4
22	4.1	3.1
30	4.5	3.5
63	5.8	4.6
80	6.4	5.0
100	7.0	5.4
110	7.3	5.5

*As per AS1940-2004 table 5.4 and clause 1.4.55, definition of protected place.
All separation distances are for combustible liquids.