

CERTIFICATE OF COMPLIANCE – DESIGN

To:
Whom it may concern

From:
Transtank Pty Ltd
6 Translink Drive
Keilor Park Vic 3042

Item:
Self bunded fuel storage tanks

Flammable and combustible liquid tanks nominal capacities of: 2250 litres (T2.25)
4500 litres (T4.5)
10,000 litres (T10)
12,000 litres (T12)
20,000 litres (T20)
30,000 litres (T30)
55,000 litres (T55)

Combustible liquid nominal capacities of:
68,000 litres (T68)
80,000 litres (T80)
90,000 litres (T90)
105,000 litres (T105)
110,000 litres (T110)

I have examined the design and I certify that the tanks and the installation of the incorporated 375 litre day tank arrangement have been constructed in accordance with the relevant codes as detailed below.

Design Documents.

Australian Standards:-	AS1940 (part 5.9 and 5.14)	The storage and handling of flammable and combustible liquids.
	AS1692,	Tanks for flammable and combustible liquids.

I also note that this tank design has passed all tests required for acceptance by UL and ULC
All tanks are pressure tested before they leave the factory.

Signed

Phil Kemm
(member AIDGC)



.....
Date: 19.02.2008